

STOP CORONA

WEAR MASK

MAINTAIN SOCIAL DISTANCE



**DELHI JAL BOARD: GNCTD  
CENTRAL LABORATORY WTP WAZIRABAD, DELHI-54**



**TEST REPORT**

Sample ID	Ref.No. D.J.B/CWA/Wzd./2022/paid-209,210		
Location /Address of Sample	Chhotu Ram Public School, Bakhtawarpur, Delhi-36		
Name of Work	--		
Reference No.	434/1/61/Extn/CRPS/2022	Ref. Letter Date	08.12.2022
Challan No.	271	Challan Date	12.12.2022
Sample Collection date	14.12.2022	Analysis date	14.12.2022
Any other Information	--	Reporting date	17.12.2022

**TEST RESULTS**

S.N.	Parameters	Unit	As per the IS 10500		Inlet	Outlet
			Desirable limit	Permissible limit		
1	Turbidity	NTU	1	5	1.97	1.30
2	pH Value	--	6.5-8.5	No relaxation	7.89	7.48
3	Colour	Pt-Co	5	15	Clear	Clear
4	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
5	Electrical Conductivity	µs/cm	-	-	1310	210
6	Total Dissolved Solids	Mg/l	500	2000	851	137
7	Total Alkalinity as CaCO <sub>3</sub>	Mg/l	200	600	216	44
8	Total Hardness as CaCO <sub>3</sub>	Mg/l	200	600	284	48
9	Calcium as Ca	Mg/l	75	200	68.80	11.28
10	Magnesium as Mg	Mg/l	30	100	26.88	4.80
11	Ammonical-Nitrogen	Mg/l	NIL	0.5	ND	ND
12	Nitrate	Mg/l	--	45	6.8	2.7
13	Chlorides as Cl	Mg/l	250	1000	210	28
14	Fluoride as F	Mg/l	1.0	1.5	0.93	0.44
15	Sulphate as SO <sub>4</sub>	Mg/l	200	400	78.3	4.2
16	T. Iron	Mg/l	--	1.0	0.16	0.04
17	Residual Chlorine	Mg/l	0.2	1.0	1.0	ND
18	COLIFORM COUNT AT 37 <sup>0</sup> C	MPN/100 ml	Absent	--	0	0

.....End of Report.....

**Remarks : For the tested parameters Water sample confirm IS-10500 and can be fit for drinking purpose.**

*[Signature]*  
ACWA  
Analysis  
14.12.2022

*[Signature]*  
CHEMIST

*[Signature]*  
A/CHEMIST



**SCHOOL HEALTH CERTIFICATE**

D. No. DHO/NRZ/2022/D-809.....

DATE:- 28/9/22..

DATE OF INSPECTION : 28/09/2022

1. NAME OF SCHOOL : **CHHOTU RAM PUBLIC SCHOOL**
2. ADDRESS : VILLAGE BAKHTAWAR PUR, DELHI-36
3. NO. OF SHIFTS : ONE TIMING: 08:00 AM TO 01:30 PM

ACCOMODATION PROVIDED:-

THE FLOOR AREA IN THE CLASSROOM IS **SUFFICIENT.**

THE CLASSES ARE **WELL LIGHTED.**

THE CLASSROOMS ARE **WELL VENTILATED.**

THE CLASSROOMS ARE **KEPT NEAT AND CLEAN.**

THE DRINKING WATER IS **DELHI JAL BOARD.**

THE TOILET ARRANGEMENT IS **SANITARY &HYGIENIC AND SUFFICIENT IN NUMBER.**

REMARKS: THIS CERTIFICATE DOES NOT INDICATES PERMISSIBILITY FROM LAND POINT OF VIEW.

The certificate is valid for a period of one year from the date of issue.

**The PRINCIPAL**

**CHHOTU RAM PUBLIC SCHOOL**

VILLAGE BAKHTAWAR PUR, DELHI-36

  
**DY. HEALTH OFFICER**

NARELA ZONE  
**Dy. Health Officer**  
Narela Zone